

LAB ID # 11216
LAB ID # 11827

Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.
Sayre, PA 18840

Phone: (570) 888-0169

Fax: (570) 888-0717

Work Order: 10012200

SEND DATA TO:

NAME: Dana Harris
COMPANY: Wellsville Water Treatment Plant
ADDRESS: 111 W. State Street
Wellsville, NY 14895

WO#: 10012200

PAGE: 1 of 3

PO#:

PHONE: (585) 593-3333

FAX: (585) 593-5864

TEST REPORT

PWS ID# 0200327-Allegany Co. DO

Drinking Water

RECEIVED FOR LAB BY: DLM2

DATE: 01/20/2010 16:18

Page 1 of 3

SAMPLE: **Entry Point #1**

Lab ID: 10012200-001A

Grab

SAMPLED BY: DLH

Sample Time: 01/20/2010 8:00

MCL

| <u>Test</u> | <u>Result</u> | <u>Method</u> | <u>MCL</u> | <u>Analysis Start</u> | <u>Analysis End</u> | <u>Analyst *</u> |
|-------------|---------------|---------------|------------|-----------------------|---------------------|------------------|
| Mercury | < 0.0002 mg/L | EPA 245.1 | 0.002 | 01/26/10 8:45 | 01/27/10 | KW-CV |
| Antimony | < 0.0005 mg/L | EPA 200.8 | 0.006 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Arsenic | < 0.0005 mg/L | EPA 200.8 | 0.01 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Barium | 0.0452 mg/L | EPA 200.8 | 2 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Beryllium | < 0.0005 mg/L | EPA 200.8 | 0.004 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Cadmium | < 0.0005 mg/L | EPA 200.8 | 0.005 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Chromium | < 0.0020 mg/L | EPA 200.8 | 0.1 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Nickel | 0.0006 mg/L | EPA 200.8 | 0.1 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Selenium | < 0.0030 mg/L | EPA 200.8 | 0.05 | 01/23/10 14:00 | 01/26/10 | JRA-CV |
| Thallium | < 0.0005 mg/L | EPA 200.8 | 0.002 | 01/23/10 14:00 | 01/26/10 | JRA-CV |

SAMPLE: **Entry Point #1**

Lab ID: 10012200-001B

Grab

SAMPLED BY: DLH

Sample Time: 01/20/2010 8:00

MCL

| <u>Test</u> | <u>Result</u> | <u>Method</u> | <u>MCL</u> | <u>Analysis Start</u> | <u>Analysis End</u> | <u>Analyst *</u> |
|-------------|---------------|---------------|------------|-----------------------|---------------------|------------------|
| Sulfate | 8.49 mg/L | EPA 300.0 | 250 | 01/25/10 15:22 | 01/25/10 | HDP-CV |

SAMPLE: **Entry Point #1**

Lab ID: 10012200-001C

Grab

SAMPLED BY: DLH

Sample Time: 01/20/2010 8:00

MCL

| <u>Test</u> | <u>Result</u> | <u>Method</u> | <u>MCL</u> | <u>Analysis Start</u> | <u>Analysis End</u> | <u>Analyst *</u> |
|-----------------|---------------|---------------|------------|-----------------------|---------------------|------------------|
| Cyanide (total) | < 0.010 mg/L | EPA 335.4 | 0.2 | 01/28/10 8:00 | 01/28/10 | KMF-SA |

SAMPLE: **Entry Point #1**

Lab ID: 10012200-001D

Grab

SAMPLED BY: DLH

Sample Time: 01/20/2010 8:00

MCL


| <u>Test</u> | <u>Result</u> | <u>Method</u> | <u>MCL</u> | <u>Analysis Start</u> | <u>Analysis End</u> | <u>Analyst *</u> |
|--------------|---------------|---------------|------------|-----------------------|---------------------|------------------|
| Nitrate as N | 0.92 mg/L | EPA 353.2 | 10 | 01/21/10 8:29 | 01/21/10 | IC-SA |

REMARKS:

The above test procedures meet all the requirements of NELAC and relate only to these samples.

* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER



DATE: 2/4/2010

LAB ID # 11216
LAB ID # 11827

Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.
Sayre, PA 18840

Work Order: 10012200

Phone: (570) 888-0169

Fax: (570) 888-0717

SEND DATA TO:

NAME: Dana Harris
COMPANY: Wellsville Water Treatment Plant
ADDRESS: 111 W. State Street
Wellsville, NY 14895

WO#: 10012200

PAGE: 2 of 3

PO#:

PHONE: (585) 593-3333

FAX: (585) 593-5864

TEST REPORT

PWS ID# 0200327-Allegany Co. DO

Drinking Water

RECEIVED FOR LAB BY: DLM2

DATE: 01/20/2010 16:18

Page 2 of 3

SAMPLE: **Entry Point #1**

Lab ID: 10012200-001F

Grab

SAMPLED BY: DLH

Sample Time: 01/20/2010 8:00

MCL


| <u>Test</u> | <u>Result</u> | <u>Method</u> | <u>MCL</u> | <u>Analysis Start</u> | <u>Analysis End</u> | <u>Analyst *</u> |
|--------------------------|---------------|---------------|------------|-----------------------|---------------------|------------------|
| Benzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Bromobenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Bromochloromethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Bromomethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| n-Butylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| sec-Butylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| tert-Butylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Carbon tetrachloride | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Chlorobenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Chloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Chloromethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 2-Chlorotoluene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 4-Chlorotoluene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Dibromomethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2-Dichlorobenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,3-Dichlorobenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,4-Dichlorobenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Dichlorodifluoromethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,1-Dichloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2-Dichloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,1-Dichloroethene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| cis-1,2-Dichloroethene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| trans-1,2-Dichloroethene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2-Dichloropropane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,3-Dichloropropane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 2,2-Dichloropropane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |

REMARKS:

The above test procedures meet all the requirements of NELAC and relate only to these samples.

* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER



DATE: 2/4/2010

LAB ID # 11216
LAB ID # 11827

Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.
Sayre, PA 18840

Work Order: 10012200

Phone: (570) 888-0169

Fax: (570) 888-0717

SEND DATA TO:

NAME: Dana Harris
COMPANY: Wellsville Water Treatment Plant
ADDRESS: 111 W. State Street
Wellsville, NY 14895

WO#: 10012200

PAGE: 3 of 3

PO#:

PHONE: (585) 593-3333

FAX: (585) 593-5864

TEST REPORT

PWS ID# 0200327-Allegany Co. DO

Drinking Water

RECEIVED FOR LAB BY: DLM2

DATE: 01/20/2010 16:18

Page 3 of 3


| | | | | | | |
|---------------------------|---------------|-----------|-------|----------------|----------|--------|
| 1,1-Dichloropropene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| cis-1,3-Dichloropropene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| trans-1,3-Dichloropropene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Ethylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Hexachlorobutadiene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Isopropylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| p-Isopropyltoluene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Methylene chloride | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/03/10 9:04 | 02/03/10 | RHH-SA |
| n-Propylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Styrene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,1,1,2-Tetrachloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,1,2,2-Tetrachloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Tetrachloroethene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Toluene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2,3-Trichlorobenzene | < 0.0010 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2,4-Trichlorobenzene | < 0.0010 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,1,1-Trichloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,1,2-Trichloroethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Trichloroethene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Trichlorofluoromethane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2,3-Trichloropropane | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,2,4-Trimethylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| 1,3,5-Trimethylbenzene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Vinyl chloride | < 0.0005 mg/L | EPA 502.2 | 0.002 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| m,p-Xylene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| o-Xylene | < 0.0005 mg/L | EPA 502.2 | 0.005 | 02/01/10 15:01 | 02/02/10 | RHH-SA |
| Methyl tert-butyl ether | < 0.0005 mg/L | EPA 502.2 | 0.01 | 02/01/10 15:01 | 02/02/10 | RHH-SA |

REMARKS:

The above test procedures meet all the requirements of NELAC and relate only to these samples.

* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER



DATE: 2/4/2010