

LAB ID # 11216 *SA
LAB ID # 11827 *CV

Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.
Sayre, PA 18840

Work Order: 11104191

Phone: (570) 888-0169
Fax: (570) 888-0717

SEND DATA TO:

NAME: Dana Harris
COMPANY: Wellsville Water Treatment Plant
ADDRESS: 111 W. State Street
Wellsville, NY 14895

WO#: 11104191

PAGE: 1 of 3

PO#:

PHONE: (585) 593-3333

FAX: (585) 593-5864

TEST REPORT

PWS ID# 0200327-Allegany Co. DO

SOCs

RECEIVED FOR LAB BY: SCP

DATE: 10/26/2011 15:17

Page 1 of 3

SAMPLE: **Entry**

Lab ID: 11104191-001A

Grab

SAMPLED BY: DH

Sample Time: 10/26/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
1,2-Dibromoethane (EDB)	< 0.00001 mg/L	EPA 504.1	0.00005	10/28/11 12:04	10/29/11	CPH-SA
1,2-Dibromo-3-chloropropane	< 0.00001 mg/L	EPA 504.1	0.0002	10/28/11 12:04	10/29/11	CPH-SA

SAMPLE: **Entry**

Lab ID: 11104191-001B

Grab

SAMPLED BY: DH

Sample Time: 10/26/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Chlordane (tech)	< 0.00010 mg/L	EPA 508	0.002	10/31/11 8:37	10/31/11	CPH-SA
Toxaphene	< 0.00025 mg/L	EPA 508	0.003	10/31/11 8:37	10/31/11	CPH-SA
PCBs as Aroclors (screen)	Absent	EPA 508	0.0001	10/31/11 8:37	10/31/11	CPH-SA

SAMPLE: **Entry**

Lab ID: 11104191-001C

Grab

SAMPLED BY: DH

Sample Time: 10/26/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Dalapon	<0.0010 mg/L	EPA 515.3	0.2	10/31/11 10:00	11/01/11	
Dicamba	<0.0010 mg/L	EPA 515.3		10/31/11 10:00	11/01/11	
2,4-D	<0.00010 mg/L	EPA 515.3	0.07	10/31/11 10:00	11/01/11	
Pentachlorophenol	<0.000040 mg/L	EPA 515.3	0.001	10/31/11 10:00	11/01/11	
Silvex	<0.00020 mg/L	EPA 515.3	0.05	10/31/11 10:00	11/01/11	
Dinoseb	<0.00020 mg/L	EPA 515.3	0.007	10/31/11 10:00	11/01/11	
Picloram	<0.00010 mg/L	EPA 515.3	0.5	10/31/11 10:00	11/01/11	

Sample Note: This sample was analyzed by Premier Laboratory, Inc. (68-04413)

SAMPLE: **Entry**

Lab ID: 11104191-001D

Grab

SAMPLED BY: DH

Sample Time: 10/26/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Alachlor	< 0.00010 mg/L	EPA 525.2	0.002	11/02/11 1:36	11/02/11	RHH-SA

REMARKS:

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless otherwise noted on the Analytical Report.

* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER

Cassie M. Davis

DATE: 11/7/2011

LAB ID # 11216 *SA
LAB ID # 11827 *CV

Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.
Sayre, PA 18840

Work Order: 11104191

Phone: (570) 888-0169
Fax: (570) 888-0717

SEND DATA TO:

NAME: Dana Harris
COMPANY: Wellsville Water Treatment Plant
ADDRESS: 111 W. State Street
Wellsville, NY 14895

WO#: 11104191

PAGE: 2 of 3

PO#:

PHONE: (585) 593-3333
FAX: (585) 593-5864

TEST REPORT

PWS ID# 0200327-Allegany Co. DO

SOCs

RECEIVED FOR LAB BY: SCP

DATE: 10/26/2011 15:17

Page 2 of 3

Compound	Concentration	Method	MCL	Start	End	Analyst
Aldrin	< 0.00010 mg/L	EPA 525.2	0.005	11/02/11 1:36	11/02/11	RHH-SA
Atrazine	< 0.00010 mg/L	EPA 525.2	0.003	11/02/11 1:36	11/02/11	RHH-SA
Benzo (a) pyrene	< 0.00010 mg/L	EPA 525.2	0.0002	11/02/11 1:36	11/02/11	RHH-SA
Di(2-ethylhexyl)adipate	< 0.00206 mg/L	EPA 525.2	0.4	11/02/11 1:36	11/02/11	RHH-SA
Di(2-ethylhexyl)phthalate	< 0.00206 mg/L	EPA 525.2	0.006	11/02/11 1:36	11/02/11	RHH-SA
Butachlor	< 0.00103 mg/L	EPA 525.2	0.05	11/02/11 1:36	11/02/11	RHH-SA
Endrin	< 0.00010 mg/L	EPA 525.2	0.002	11/02/11 1:36	11/02/11	RHH-SA
Heptachlor	< 0.00010 mg/L	EPA 525.2	0.0004	11/02/11 1:36	11/02/11	RHH-SA
Heptachlor epoxide	< 0.00010 mg/L	EPA 525.2	0.0002	11/02/11 1:36	11/02/11	RHH-SA
Hexachlorobenzene	< 0.00010 mg/L	EPA 525.2	0.001	11/02/11 1:36	11/02/11	RHH-SA
Hexachlorocyclopentadiene	< 0.00010 mg/L	EPA 525.2	0.05	11/02/11 14:32	11/02/11	RHH-SA
HCH-gamma (Lindane)	< 0.00010 mg/L	EPA 525.2	0.0002	11/02/11 1:36	11/02/11	RHH-SA
Methoxychlor	< 0.00010 mg/L	EPA 525.2	0.04	11/02/11 1:36	11/02/11	RHH-SA
Metolachlor	< 0.00103 mg/L	EPA 525.2	0.05	11/02/11 1:36	11/02/11	RHH-SA
Metribuzin	< 0.00103 mg/L	EPA 525.2	0.05	11/02/11 1:36	11/02/11	RHH-SA
Propachlor	< 0.00103 mg/L	EPA 525.2	0.05	11/02/11 1:36	11/02/11	RHH-SA
Simazine	< 0.00010 mg/L	EPA 525.2	0.004	11/02/11 1:36	11/02/11	RHH-SA
Dieldrin	< 0.00010 mg/L	EPA 525.2	0.005	11/02/11 1:36	11/02/11	RHH-SA

SAMPLE: Entry

Lab ID: 11104191-001E

Grab

SAMPLED BY: DH

Sample Time: 10/26/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Aldicarb sulfoxide	< 0.00100 mg/L	EPA 531.1	0.004	10/31/11 11:15	11/01/11	IC-SA
Aldicarb sulfone	< 0.00100 mg/L	EPA 531.1	0.002	10/31/11 11:15	11/01/11	IC-SA
Oxamyl	< 0.00100 mg/L	EPA 531.1	0.2	10/31/11 11:15	11/01/11	IC-SA
Methomyl	< 0.00100 mg/L	EPA 531.1		10/31/11 11:15	11/01/11	IC-SA
3-Hydroxycarbofuran	< 0.00100 mg/L	EPA 531.1		10/31/11 11:15	11/01/11	IC-SA
Aldicarb	< 0.00100 mg/L	EPA 531.1	0.003	10/31/11 11:15	11/01/11	IC-SA
Carbofuran	< 0.00100 mg/L	EPA 531.1	0.04	10/31/11 11:15	11/01/11	IC-SA

REMARKS:

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless otherwise noted on the Analytical Report.

* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER

Cassie M. Davis

DATE: 11/7/2011

LAB ID # 11216 *SA
LAB ID # 11827 *CV

Benchmark Analytics, Inc.
Eastern Division

2566 Pennsylvania Ave.
Sayre, PA 18840

Work Order: 11104191

Phone: (570) 888-0169
Fax: (570) 888-0717

SEND DATA TO:

NAME: Dana Harris
COMPANY: Wellsville Water Treatment Plant
ADDRESS: 111 W. State Street
Wellsville, NY 14895

WO#: 11104191

PAGE: 3 of 3

PO#:

PWS ID# 0200327-Allegany Co. DO

PHONE: (585) 593-3333
FAX: (585) 593-5864

TEST REPORT

SOCs

RECEIVED FOR LAB BY: SCP

DATE: 10/26/2011 15:17

Page 3 of 3

Carbaryl	< 0.00100 mg/L	EPA 531.1	10/31/11 11:15	11/01/11	IC-SA
----------	----------------	-----------	----------------	----------	-------

REMARKS:

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless otherwise noted on the Analytical Report.

* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER

Cami M. Davis

DATE:

11/7/2011