

LAB ID # 11216 \*SA  
LAB ID # 11827 \*CV

# Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.  
Sayre, PA 18840

Work Order: 11080690

Phone: (570) 888-0169  
Fax: (570) 888-0717

**SEND DATA TO:**

NAME: Dana Harris  
COMPANY: Wellsville Water Treatment Plant  
ADDRESS: 111 W. State Street  
Wellsville, NY 14895

WO#: 11080690

PAGE: 1 of 2

PO#:

PWS ID# 0200327-Allegany Co. DO

PHONE: (585) 593-3333  
FAX: (585) 593-5864

## TEST REPORT

**THM & HAA**

RECEIVED FOR LAB BY: TJC

DATE: 08/03/2011 17:20

Page 1 of 2

SAMPLE: **24 Herman Ave.**  
SAMPLED BY: DH

Lab ID: 11080690-001A Grab  
Sample Time: 08/03/2011 10:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Chloroform	0.0243 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Bromodichloromethane	0.0123 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Dibromochloromethane	0.00350 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Bromoform	< 0.00050 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Total Trihalomethanes	0.0401 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA

SAMPLE: **24 Herman Ave.**  
SAMPLED BY: DH

Lab ID: 11080690-001B Grab  
Sample Time: 08/03/2011 10:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Total Haloacetic Acids	0.0370 mg/L	EPA 552.2	0.06	08/08/11 9:00	08/09/11	
Monochloroacetic acid	<0.0010 mg/L	EPA 552.2	0.06	08/08/11 9:00	08/09/11	
Monobromoacetic acid	<0.00050 mg/L	EPA 552.2	0.06	08/08/11 9:00	08/09/11	
Dichloroacetic acid	0.0200 mg/L	EPA 552.2	0.06	08/08/11 9:00	08/09/11	
Trichloroacetic acid	0.0170 mg/L	EPA 552.2	0.06	08/08/11 9:00	08/09/11	
Dibromoacetic acid	<0.00050 mg/L	EPA 552.2	0.06	08/08/11 9:00	08/09/11	

Sample Note: This sample was analyzed by Premier Laboratory, Inc. (68-04413)

SAMPLE: **Entry Point**  
SAMPLED BY: DH

Lab ID: 11080690-002A Grab  
Sample Time: 08/03/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Total Organic Carbon	1.2 mg/L	SM5310C		08/05/11 17:30	08/06/11	KAL-SA

SAMPLE: **Source**  
SAMPLED BY: DH

Lab ID: 11080690-003A Grab  
Sample Time: 08/03/2011 9:00

Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst *
Total Organic Carbon	1.9 mg/L	SM5310C		08/05/11 17:30	08/06/11	KAL-SA

**REMARKS:**

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless otherwise noted on the Analytical Report.

\* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER

*Carrie M. Davis*

DATE: 8/16/2011

LAB ID # 11216 \*SA  
LAB ID # 11827 \*CV

# Benchmark Analytics, Inc. Eastern Division

2566 Pennsylvania Ave.  
Sayre, PA 18840

Work Order: 11080690

Phone: (570) 888-0169  
Fax: (570) 888-0717

SEND DATA TO:

NAME: Dana Harris  
COMPANY: Wellsville Water Treatment Plant  
ADDRESS: 111 W. State Street  
Wellsville, NY 14895

WO#: 11080690

PAGE: 2 of 2

PO#:

PWS ID# 0200327-Allegany Co. DO

PHONE: (585) 593-3333  
FAX: (585) 593-5864

## TEST REPORT

THM & HAA

RECEIVED FOR LAB BY: TJC

DATE: 08/03/2011 17:20

Page 2 of 2

SAMPLE: THM-TB

Lab ID: 11080690-004A

Grab

SAMPLED BY: SCP

Sample Time: 06/20/2011 12:00

<u>Test</u>	<u>Result</u>	<u>Method</u>	<u>Reg Limit</u>	<u>Analysis Start</u>	<u>Analysis End</u>	<u>Analyst *</u>
Chloroform	< 0.00050 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Bromodichloromethane	< 0.00050 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Dibromochloromethane	< 0.00050 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Bromoform	< 0.00050 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA
Total Trihalomethanes	< 0.00050 mg/L	EPA 524.2	0.08	08/08/11 19:50	08/08/11	KMT-SA

REMARKS:

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless otherwise noted on the Analytical Report.

\* CV = Benchmark Analytics, Inc. Center Valley, PA; SA = Benchmark Analytics, Inc. Sayre, PA

MANAGER

*Carrie M. Davis*

DATE:

8/16/2011